



Product Service

# C E R T I F I C A T E

No. Z2 127292 0006 Rev. 01

**Holder of Certificate:** **Sunshare Technology Co., Ltd.**

2nd Floor, Building A  
No. 2999 Jiayin Avenue, Jiangning District  
211100 Nanjing City, Jiangsu Province  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704062474201-01

**Valid until:** 2030-05-29

**Date,** 2025-06-06

( Zhulin Zhang )

# C E R T I F I C A T E

No. Z2 127292 0006 Rev. 01

**Model(s):**

SR-MxxxT-T64B1 (xxx=190 to 200, in steps of 5)

SR-MxxxT-T64B (xxx=180 to 190, in steps of 5)

SR-MxxxT-T64W (xxx=190 to 200, in steps of 5)

SR-MxxxT-H66B (xxx= 275 to 285, in steps of 5)

xxx stands for rated output power at STC.

**Parameters:**

Construction: Framed with Junction box, Cable and Connectors.

Safety Class: Class II

Maximum System Voltage: 600 V DC or 1000V DC

Fire Safety Class: Class C according to UL790

Test Laboratory: Changzhou HuaYang Inspection and Testing Technology Co., Ltd. B Area on 1/F., Building 12, C Area on 4/F., and A Area on 1/F., Building 10, No.8, Lanxiang Road, West Taihu Science and Technology Industrial Park, Changzhou, Jiangsu, China

**Tested  
according to:**

IEC 61215-1:2021

IEC 61215-1-1:2021

IEC 61215-2:2021

IEC 61730-1:2023

IEC 61730-2:2023